



HDPE TO PVC CONNECTION
FOR UP TO 12" PIPE

N.T.S.

GENERAL NOTES

1. WRAP SOLID SLEEVE 6 MIL THICK POLYETHYLENE 2 FEET BEYOND FITTINGS.
2. CONCRETE ANCHOR SHALL BE 4'X4'X3" (HXMXL) FOR UP TO 12" PIPE. CONCRETE ANCHOR SHALL BE DESIGNED BY A PROFESSIONAL ENGINEER FOR PIPE LARGER THAN 12".
3. BACKFILL AND COMPACT IN 6" LIFTS. COMPACTION SHALL BE TO A MINIMUM OF 95% COMPACTION.
4. ALL BOLTS AND NUTS SHALL BE STAINLESS STEEL.

STANDARDS

1. AWWA C153
2. AWWA C900
3. AWWA C901

MANUFACTURER

1. SIP, SIGMA, ROMAC - MU JOINTS & RINGS
2. USA MADE!

ISSUE DATE: SEPTEMBER 2018

TOWN & VILLAGE OF ELLICOTTVILLE

REVISIONS	DATE	COMMENTS

EVL ENG DEPT.
WATER - W-06

